

NAFS Certification Data

Product Line Code	Product Description	Size	Design Pressure	TstRpt#	Cert / Exp	Standard
ET68-UC2 Double Casement Outswing Window	Standard Glazed	70" x 70"	Class LC-PG25; Size Tested 1778.2 (70.00") x 1778.2 (70.00") Type-C; DP +25/-25 psf; Water Test Press 180Pa (3.76psf)	SV31736 – 20210901-Rev 1	10/18/2021 5/5/2031	101/I.S.2/A440-17
ET68-UC2 Double Casement Outswing Window	Standard Glazed	70" x 70"	Class LC-PG25; Size Tested 1778.2 (70.00") x 1778.2 (70.00") Type-C; DP +25/-25 psf; Water Test Press 180Pa (3.76psf)	SV31736 – 20210901-Rev 1	10/18/2021 5/5/2031	101/I.S.2/A440-11
ET68-UC2 Double Casement Outswing Window	IG Impact Glazed	70" x 70"	Class LC-PG35; Size Tested 1778 (70.00") x 1778 (70.00") Type-C; DP +35/-45 psf; Water Test Press 290Pa (6.06psf)	QCT21-6453.03	11/19/2021 10/19/2031	101/I.S.2/A440-17
ET68-UC2 Double Casement Outswing Window	IG Impact Glazed	70" x 70"	Class LC-PG35; Size Tested 1778 (70.00") x 1778 (70.00") Type-C; DP +35/-45 psf; Water Test Press 290Pa (6.06psf)	QCT21-6453.03	11/19/2021 10/19/2031	101/I.S.2/A440-11
ProdLineName	Product Description	Size	Design Pressure	TstRpt#	Cert / Exp	Standard
ET68-FN Fixed Window	Standard Glazed	84" x 144"	Class LC-PG50; Size Tested 2134mm (84.00") x 3658mm (144.00") Type-FW; DP +50/-50 psf; Water Test Press 720Pa (15.04psf);	SV31736 – 20210312	9/7/2021 3/12/2031	101/I.S.2/A440-11
ET68-FN Fixed Window	Standard Glazed	84" x 144"	Class LC-PG50; Size Tested 2134mm (84.00") x 3658mm (144.00") Type-FW; DP +50/-50 psf; Water Test Press 720Pa (15.04psf);	SV31736 – 20210312	9/7/2021 3/12/2031	101/I.S.2/A440-17
ET68-FN Fixed Window	IG Impact Glazed	66" x 120"	Class LC-PG35; Size Tested 1676mm (66.00") x 3048mm (120.00") Type-FW; DP +35/-45 psf; Water Test Press 360Pa (7.52psf);	QCT21-6453.05	4/4/2022 3/22/2032	101/I.S.2/A440-17
ET68-FN Fixed Window	IG Impact Glazed	66" x 120"	Class LC-PG35; Size Tested 1676mm (66.00") x 3048mm (120.00") Type-FW; DP +35/-45 psf; Water Test Press 360Pa (7.52psf);	QCT21-6453.05	4/4/2022 3/22/2032	101/I.S.2/A440-11
ProdLineName	Product Description	Size	Design Pressure	TstRpt#	Cert / Exp	Standard
ET68UD Series Steel Exterior Out-Swing Thermally Broken Door	IG Impact Glazed	84" x 120"	Class LC-PG35; Size Tested 2134mm (84.00") x 3048mm (120.00") Type-SHD; DP +35/-45 psf; Water Test Press 260Pa (5.43psf)	QCT21-6453.02-R1	4/5/2022 11/16/2031	101/I.S.2/A440-17
ET68UD Series Steel Exterior Out-Swing Door with Thermal Break	IG Impact Glazed	84" x 120"	Class LC-PG35; Size Tested 2134mm (84.00") x 3048mm (120.00") Type-SHD; DP +35/-45 psf; Water Test Press 260Pa (5.43psf)	QCT21-6453.02-R1	4/5/2022 11/16/2031	101/I.S.2/A440-11
ProdLineName	Product Description	Size	Design Pressure	TstRpt#	Cert / Exp	Standard
ET68WD Series Steel Exterior In-Swing Door with Thermal Break	IG Impact Glazed	84" x 120"	Class LC-PG35; Size Tested 2134mm (84.00") x 3048mm (120.00") Type-LW-SHD; DP +35/-45 psf; Water Test Press 0Pa (0.00psf)	QCT21-6453.01-R1	4/5/2022 10/24/2032	101/I.S.2/A440-17
ET68WD Series Steel Exterior In-Swing Door with Thermal Break	IG Impact Glazed	84" x 120"	Class LC-PG35; Size Tested 2134mm (84.00") x 3048mm (120.00") Type-LW-SHD; DP +35/-45 psf; Water Test Press 0Pa (0.00psf)	QCT21-6453.01-R1	4/5/2022 10/24/2032	101/I.S.2/A440-11